



The Town of Vienna 2009 Annual Water Quality Report for the Town of Vienna and the surrounding service area

MESSAGE FROM THE TOWN MANAGER

This is the Town of Vienna's eleventh annual report to inform you about your drinking water quality. As a part of the Safe Drinking Water Act of 1996, the U.S. Environmental Protection Agency (EPA) requires all water utilities across the nation to mail their customers a Water Quality Report by July 1, 2009. Our goal is to provide you with a safe and dependable supply of drinking water, and we want you to understand our efforts to protect your water supply.

The quality of your drinking water must meet state and federal requirements administered by the Virginia Department of Health. We constantly monitor for various contaminants in the water supply to meet all regulatory requirements. The tables in this report list only those contaminants that had some level of detection. Many other contaminants have been analyzed but were either not present or were below the detection limits of the laboratory equipment. All of our water quality data are from testing done in 2008. However, the Commonwealth allows us to monitor for some contaminants less than once a year because the concentration of these contaminants does not change frequently. Even though some of our data may be more than one year old, they are accurate.

Is your water safe to drink? Absolutely! The Town of Vienna water system had only one minor violation during the year. We're proud to share our water quality test results with you. Also, a "source water assessment" of our system has been conducted by the Virginia Department of Health. Wells #1 & #9 were determined to be of high susceptibility to contamination using the criteria developed by the state in its approved Source Water Assessment Program. This report consists of maps showing the assessment area, land use activities, and records of any contamination within the last five years. For further information, please call the contact number below.

Sincerely,

John H. Schoeberlein

John H. Schoeberlein
Town Manager

This report contains important information about your drinking water. If you are not certain that you understand it, discuss it with someone who does or who can translate it for you if English is your second language. For more information, contact Roscoe Johnson, Acting Town of Vienna Water & Sewer Superintendent, at 703-319-8612 or e-mail rjohnson@viennava.gov.

El informe contiene información importante sobre la calidad del agua en su comunidad. Tradúzcalo o hable con alguien que lo entienda bien.

OPPORTUNITIES FOR PUBLIC PARTICIPATION

Decisions concerning Vienna's water are made by the Town Council. Regular meetings are normally held the first and third Mondays of the month (except July and August) at 8 p.m. in the Council Chamber at Town Hall.

GENERAL INFORMATION

As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and can pick up substances resulting from the presence of animals or from human activity. Substances (referred to as contaminants) in source water may come from septic systems, discharges from domestic or industrial wastewater treatment facilities, agricultural and farming activities, urban storm water runoff, residential uses, and many other types of activities. Water from surface sources is treated to make it drinkable while groundwater may or may not have any treatment.

All drinking water, including bottled drinking water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. Environmental Protection Agency/Center for Disease Control guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline.

WATER SOURCES

For the calendar year 2008, the Town of Vienna was supplied with treated surface water from the Potomac River by the Fairfax County Water Authority (FCWA) and the City of Falls Church. The Town purchases treated water from the Washington Aqueduct supplied by Falls Church. The final source is groundwater from two wells in the Town of Vienna. Well water is blended in the Town's delivery system and comprises approximately 1% of our total usage.

HOW DO I READ THIS CHART?

Our water is tested to assure that it is safe and healthy. Contaminants in the drinking water are routinely monitored according to Federal and State regulations. The table contained in this report shows the most recent results of our monitoring. Typical sources of contamination show where this substance usually originates. The following definitions are provided to help you better understand terms and abbreviations.

- The FCWA sampling program includes cryptosporidium. Their results and information are included.
- Non-detects (ND) – laboratory analysis indicates that the contaminant is not present.
- Parts per million (ppm) – one part per million corresponds to one minute in two years or a single penny in \$10,000.
- Parts per billion (ppb) – one part per billion corresponds to one minute in 2,000 years or a single penny in \$10,000,000.
- Parts per trillion (ppt) – one part per trillion corresponds to one minute in 2,000,000 years or a single penny in \$10,000,000,000.
- Picocuries per liter (pCi/L) – picocuries per liter is a measure of the radioactivity in water.
- Nephelometric Turbidity Unit (NTU) – nephelometric turbidity unit is a measure of the clarity, or cloudiness, of water. Turbidity in excess of 5 NTU is just noticeable to the average person. Turbidity is monitored because it is a good indicator of the effectiveness of the filtration system.
- Action Level (AL) – the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- Treatment Technique (TT) – a required process intended to reduce the level of a contaminant in drinking water.
- Maximum Contaminant Level (MCL) – the highest level of a contaminant that is allowed in drinking water. MCLs are set at very stringent levels by the U.S. Environmental Protection Agency. In developing the standards EPA assumes that the average adult drinks two liters of water each day throughout a 70-year life span. EPA generally sets MCLs at levels that will result in no adverse health effects for some contaminants or a one-in-ten-thousand to one-in-one million chance of having the described health effect for other contaminants.
- Maximum Contaminant Level Goal (MCLG) – the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- Maximum Residual Disinfectant Level (MRDL) – the maximum level of total chlorine allowable by regulation.

PERCHLORATE RESEARCH

Perchlorate is a naturally occurring as well as man-made compound. Its presence in drinking water is currently unregulated and utilities are not required to monitor for it. In 2007, the Washington Aqueduct and Fairfax Water began voluntarily participating in a non-regulatory perchlorate sampling project for the Potomac River funded by the EPA, which has established a reference dose of 24.5 ppb for perchlorate. A reference dose is a scientific estimate of a daily exposure level that is not expected to cause adverse health effects in humans, and will be used in EPA's ongoing efforts to address perchlorate in drinking water.

The samples collected in 2008 from our Potomac River water filtration plant sources and treated water have shown amounts of perchlorate at 1.1 ppb or less, far below the EPA reference dose level. More information about perchlorate and the Washington Aqueduct's participation in the EPA's sampling project is available at <http://www.epa.gov/reg3wapd/drinking/dc.htm>.

LEAD IN DRINKING WATER

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Town of Vienna is responsible for providing high quality drinking water, but cannot control the variety of materials used in private plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at www.epa.gov/safewater/lead or by calling the Safe Drinking Water Hotline at 1-800-426-4791, TTY 711.

TURBIDITY IN DRINKING WATER

Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated headaches.

2008 SOURCE WATER *CRYPTOSPORIDIUM* INFORMATION

The Town's water suppliers have been monitoring the source waters for compliance with the EPA's Long Term 2 Enhanced Surface Water Treatment Rule (LT2ESWTR). The EPA created this rule to provide for increased protection against microbial pathogens, such as *Cryptosporidium*, in public water systems that use surface water sources.

Even though monitoring has been completed for the LT2ESWTR, the Town's suppliers have continued to test for *Cryptosporidium*, and the data collected in 2008 are summarized in the table below.

Source (before treatment)	Average <i>Cryptosporidium</i> concentration (oocysts/Liter)
Potomac River	0.0675
Occoquan Reservoir	0

WATER QUALITY RESULTS

I. Microbiological Contaminants – Were there any detections? (✓) Yes, as described below. () No.
Laboratory results indicated that coliform bacteria were present in one test out of 384 samples.

II. Lead and Copper Contaminants – Were there any detections? (✓) Yes, as described below. () No.

Contaminant	Units of Measurement	Action Level	MCLG	Results of Samples for the 90 th Percentile Value	Action Level Exceedance?	Sampling Year	# of Sampling Sites Exceeding Action Level	Typical Source of Contamination
Lead	ppb	15	0	1.90	NO	2008	0	Corrosion of household plumbing systems
Copper	ppm	1.3	1.3	0.08	NO	2008	0	Corrosion of household plumbing systems

III. Turbidity – Were there any detections? (✓) Yes, as described below. () No.

Contaminant	Treatment Technique Limits	Level Detected	Violation?	Sampling Year	Typical Source of Contamination
Turbidity	1. 1 NTU maximum 2. 0.3 – 95% of the time	1. highest single measurement = >1.0 2. lowest monthly percentage = 99.922%	**YES NO	2008 2008	Soil runoff

**Treatment Technique violation.

IV. Other Chemical and Radiological Contaminants – Were there any detections? (✓) Yes, as described below. () No.

Inorganic/Synthetic/ and Metals	Units of Measurement	MCLG	MCL	Level Detected	Violation?	Range of Detection at Sampling Points	Sampling Year	Typical Source of Contamination
Arsenic	ppb	0	10	0.67	NO	ND-0.67	2008	Erosion of natural deposits; runoff from orchards/manufacturing of glass and electrical products
Atrazine	ppb	3	3	0.07	NO	ND-0.07	2008	Runoff from herbicide used on row crops
Barium	ppm	2	2	0.05	NO	0.03-0.05	2008	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Chromium	ppb	100	100	3	NO	0.8-3	2008	Erosion of natural deposits, discharge from steel mills
Di-(2-ethylhexyl) phthalate	ppb	0	6	0.9	NO	ND-0.9	2008	Discharge from rubber and chemical factories
Mercury	ppb	2	2	0.55	NO	ND-0.55	2008	Erosion of natural deposits, discharge from factories, runoff
Selenium	ppb	50	50	1.4	NO	0.4-1.4	2008	Erosion, discharge from petroleum refineries and mines
Fluoride	ppm	4	4	1.1	NO	0.62-1.1	2008	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate (Nitrogen)	ppm	10	10	3.4	NO	0.4-3.4	2008	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Nitrite (Nitrogen)	ppm	1	1	0.06	NO	ND-0.06	2008	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Nitrate+Nitrite=N	ppm	10	10	3.4	NO	ND-3.4	2008	Same as separate Nitrate/Nitrite

* No MCL, not considered a health risk.

Contaminant/DBPs/ Disinfection Byproducts	Running Annual MCLG (ppb)	Average MCL (ppb)	System Running Annual Average (ppb)	System Range (ppb)	Violation?	Sampling Year	Typical Source of Contamination
TTHMs [Total Trihalomethanes]	N/A	80	45	5-99	NO	2008	Byproduct of chlorination
Haloacetic Acids(5)	N/A	60	31	3-59	NO	2008	Byproduct of chlorination
Chloramines	4 ppm	4 ppm	3 ppm	0.1–4.0	NO	2008	Disinfection additive
Chlorine	4 ppm	4 ppm	3.1 ppm	0.4–4.8	NO	2008	Disinfection additive
Total Organic Carbon	N/A	TT	*Ratio >1.20	1.00–1.64	NO	2008	Naturally present in the environment

*Removal Ratio must be greater than 1.00.

Radionuclides	Units of Measurement	MCLG	MCL	Highest Level Detected	Range of Detection	Violation?	Sampling Year	Typical Source of Contamination
Alpha emitters	pCi/L	0	15	0.29	0.08 – 0.29	NO	2008	Erosion of natural deposits
Beta emitters	pCi/L	0	50	4.3	ND – 4.3	NO	2008	Decay of natural and man-made deposits
Radium 228	pCi/L	0	5	2.0	ND – 2.0	NO	2008	Erosion of natural deposits

Town of Vienna
127 Center Street, South
Vienna, Virginia 22180-5799

PRSRT STD
U.S. POSTAGE
PAID
Vienna, VA
Permit No. 36

2009 WATER QUALITY REPORT